


FLOOR PLAN
SCALE: 1/4"=1'-0"

NOTE:
MATE LINE WALLS TO HAVE
DOUBLE TOP PLATES









CABINET ELEVATION
SCALE: 1/4" = 1'-0"

COLUMN STRAPPING SCHEDULE	
(A) (2) 2x4 SYP#2 (THIS HALF)	(B) (2) 2x4 SYP#2 (EACH HALF)
(C) (3) 2x4 SYP#2 (THIS HALF)	(D) (3) 2x4 SYP#2 (EACH HALF)
(E) (4) 2x4 SYP#2 (THIS HALF)	(F) (4) 2x4 SYP#2 (EACH HALF)
(G) (2) 2x6 SYP#2 (THIS HALF)	(H) (2) 2x6 SYP#2 (EACH HALF)

NOTES:
ALL COLUMN STUDS SHALL BE GLUED/NAILED TOGETHER
P.V.A. GLUE W/ 100% COVERAGE SHALL BE USED
INSTALL TWO (2) STEEL STRAPS AT EACH STUD OF EACH COLUMN
COLUMN STUDS SHALL NOT BE NOTCHED OR BORED.
STEEL STRAPS SHALL BE (2) 26 GA. x 1 1/2" FASTENED WITH (14)
16 GA. x 7/16" CROWN x 1 1/4" STAPLES PER DOUBLE STRAP
END OR EQUAL, FROM RIDGE BEAM TO COLUMN AND COLUMN TO FLOOR.
* = BEARING STIFFNER

PLYWOOD RIDGE BEAM SPECS		
UNIT	LOCATION	LAYERS OF PLYWOOD BEAM
A	A-SIDEWALL	2 LAYERS 3/4"x 24"
A-B		4 LAYERS 3/4"x 24"
B	B-A	4 LAYERS 3/4"x 24"
B-C		4 LAYERS 3/4"x 24"
C	C-D	4 LAYERS 3/4"x 24"
C-B		4 LAYERS 3/4"x 24"
D	D-C	4 LAYERS 3/4"x 24"
D-SIDEWALL		2 LAYERS 3/4"x 24"

APA RATED PLYWOOD, EXP-1, STRUCT. 1,
5 PLY, 5 LAYER, 48/24



PROJECT HISTORY
START DATE: 04/20/16
Customer Changes: 04/25/16
Customer Changes: 04/26/16
3rd Party Comments: 04/26/16

MBSI
FLEET OFFICE BUILDING 2
SN: 19201 A-D
FLOOR PLAN

Southeast Modular
Manufacturing
Corporate Office
2500 INDUSTRIAL STREET
LEESBURG, FLORIDA 34748



Digitally signed by Thomas L. Melton
DN: cn=US, o=IdenTrust ACES Unaffiliated Individual, cn=Thomas L. Melton,
0.9.2342.19200300.100.1.1= A010980000015015C7345 10000E608
Date: 2016.04.27 16:40:47 -04'00'

LISTING AGENCY APPROVAL	
CONST. TYPE	V-B
OCCUPANCY	B-BUSINESS
ALLOWABLE NO. OF FLOORS	1
RISK CATEGORY	II
WIND VELOCITY (ULT)	160 MPH
WIND VELOCITY (ASD)	124 MPH
FIRE RATING OF EXT. WALLS	0
PLAN NO.	1578-5086F
ALLOW. FLOOR LOAD	50/100 PSF
APPROVAL DATE	4-23-16
MANUFACTURER	SMM
HIGH VELOCITY HURRICANE ZONE	NO

THOMAS L. MELTON
1074 S. FLORIDA AVENUE
LAKELAND, FL. 33803

THIRD PARTY: HILBORN, WERNER, CARTER & ASSOCIATES
1627 SOUTH MYRTLE AVE.
CLEARWATER, FLORIDA 33756

DRAWN BY: CH
CHECKED BY: TM
DATE: 04/20/16
SCALE: 1/4"=1'-0"
HWC# 1578-5086F
SERIAL# 19201 A-D
SHEET: 3